



VILLAGE OF POINT EDWARD

SUBMITTED BY: Jason Verstraeten, Manager of Environmental Services

Water/Wastewater Treatment Plant Committee for the month ending December 31, 2019

RECOMMENDATION

THAT the Committee receive and file the Water/Wastewater Treatment Plant Committee Monthly Report.

UPDATES FROM PREVIOUS MONTH

- Digester Project – the test in December failed and Maaten has been informed they are to go back to the original scope of work to repair and seal the digester by MIG.
- Roof work will be done after digester 1 & 2 are completed.
- Kendall Pump Station safety railing was installed, this project is complete.
- Private fire hydrants and valves - Jim and I will be reviewing the documents that have been found and will look at alternative options if required over 2019.
- By-law amendments and reviews – Jim and I are working at revising the water and wastewater by-laws through 2020
- Budget has been drafted and final budget request will be presented to council

WORK MANAGEMENT

Staff

- 4 FTE compliment this month. No staffing related matters to discuss currently.

Training

- All staff will be doing the required training to maintain and/or gain higher level certification.

Certifications

- All staff certifications are valid and up to date.

TREATMENT PLANT

Interior

- Regular maintenance is being performed and there have been no major deficiencies have been identified at this time.

Exterior

- Regular maintenance being performed to keep the appearance of the facility above the expectations of the Village. There are some repairs that need to be made to the roof access ladders of a couple buildings which will be looked at in the spring 2020. There have been no major deficiencies identified this month
- Office roof repairs can not be done until we have more information from Maaten and MIG as to the digester repairs after the failure of the last test.



VILLAGE OF POINT EDWARD

SUBMITTED BY: Jason Verstraeten, Manager of Environmental Services

Inspections

- Environment Canada report has not been issued at this time from their inspection.

WASTE WATER INFRASTRUCTURE

- All the remote assets are in good operational condition to the best of the MES knowledge.

CLEAN WATER INFRASTRUCTURE

- No issues at this time to report on.

INSPECTIONS, AUDITS & REPORTS

- The 2019 annual reporting for water and waste water has started and will be completed over the next few months.

VEHICLES & EQUIPMENT

- All vehicles and equipment in good operating condition.

HEALTH & SAFETY

- Please see the attached H&S reports submitted. No major issues identified at this time known to the department

SECURITY

- The fence at the rear of the plant requires some repair or replacement. It is our thoughts that the fence is owned by the BWBA but the claim it is Village owned. MES will contact the new operation person at the BWBA to discuss. Jim and Bev to discuss with Bridge Auth. Ongoing

CAPITAL BUDGET

- The 2020 has been drafted and will be presented for approval

COMMUNITY FEEDBACK

No correspondence received

UPCOMING EVENTS

- No upcoming events to discuss

CLOSING COMMENTS